

## CERTIFICATE OF ANALYSIS

Date	: 17-04-2025
Sample ID No.	: EL/250410-006

Name & Address of Customer	: GREENWOOD SCHOOL Haripar, Rajkot, Gujarat, India
*Material	: Borewell water
Date of Sample Receiving	: 10-04-2025
Sample Quantity	: 2 Ltr.
Date of Sample Testing	: 10-04-2025 to 14-04-2025
Sampled By	: Client
Packaging Condition	: Plastic bottle packing

Sr.No.	Test Parameter	Unit	Test Result	Requirement
<b>Chemical Testing</b>				
1	pH at 25°C	-	7.24	6.5 - 8.5
2	Turbidity	NTU	0.1	1.00 max.
3	Calcium (as Ca)	mg/l	1.59	75 max.
4	Magnesium (as Mg)	mg/l	1.07	30 max.
5	Conductivity	mS/cm2	0.058	-
6	Total Dissolved Solids	mg/l	42	500 max.
7	Total Hardness	mg/l	12.04	200 max.
8	Nitrate (as NO3)	mg/l	B.D.L. (D.L.= 1.0)	45 max.
9	Sulphate (as SO4)	mg/l	B.D.L. (D.L.= 1.0)	200 max.
10	Alkalinity (as CaCO3)	mg/l	8.16	200 max.
11	Chloride (as Cl)	mg/l	11.99	250 max.
12	Fluoride (as F)	mg/l	B.D.L.(D.L.=0.25)	1.0 max.
13	Silica	mg/l	< 5	-
<b>Biological Testing</b>				
1	E.coli	Detection/100 ml	Absent	Shall not be detectable in any 100 ml sample
2	Coliform	Detection/100 ml	Absent	Shall not be detectable in any 100 ml sample

### Remarks:

1. This report, in full or in part, shall not be published, advertised, used for any legal action, unless prior permission has been secured from The Director, ENVITRO LABORATORIES PVT. LTD. RAJKOT.
2. The test report pertains to the sample tested.
3. All above Parameters are not covered/Not accredited under NABL Scope of Accreditation.
4. \* The details are received from customer on their own responsibility, Envitro Laboratories Pvt. Ltd. does not confirm about it, and hence does not take any responsibility whatsoever.

*Rajesh*  
ANALYZED BY

*Mukesh Parmar*  
AUTHORIZED SIGNATORY  
Name - MUKESH PARMAR  
(Chemical)

*Mukesh Parmar*  
AUTHORIZED SIGNATORY  
Name - MUKESH PARMAR  
(Biological)



\*\*\*\* END OF REPORT \*\*\*\*